

Lightning Protection

R. H. Golde, Dipl. Ing., Ph.D., D.Sc. (Eng.), F.I.E.E.



Edward Arnold

Contents

GOLDE: LIGHTNING PROTECTION

ERRATUM

Page 37 . . . three lines from bottom of page:

The Publisher regrets that this sentence is not precisely in accordance with the reference given and should read as follows:

For this purpose a variety of radio-active sources, including Americium 241 (Berio, 1970) have been fitted below the tip of a lightning rod and the claim has been advanced that a single such rod would ensure protection within a radius of 250 m. Berio furthermore states that these claims have been substantiated by theoretical considerations and statistical experiences.

Page 27 . . . equation (1) should read:

$$Q = Q_0 e^{-\beta h}$$

Page 51 . . . In 3rd and 4th paragraph of chapter 5.3:

read $\int i^2 dt$ for $\int i^2 t dt$

Page 52 . . . On abscissa of Fig. 23 read 10^{-1} for 10^1

Page 97 . . . For $L = 1.6$ henry/m = $1.6 \times 10^{-6} \frac{h}{n}$ henry

read $L = 1.6 \mu$ henry/m = $1.6 \times 10^{-6} \frac{h}{n}$ henry

Page 179 . . . line 24—for 100Ω read 700Ω .

Contents

Preface	v
1 Historical survey	1
2 The thunderstorm	3
2.1 Global distribution of thunderstorms	3
2.2 The thundercloud	5
2.3 Point-discharge currents	7
3 The lightning discharge	9
3.1 Temporal development of flash to ground	9
3.2 Strokes to tall structures	12
3.3 Lightning currents and related parameters	15
3.4 Frequency of lightning discharges	19
4 The lightning conductor	23
4.1 Mechanism of strike	23
4.2 Striking distance	26
4.3 Protective zone	31
4.4 Radio-active lightning conductors	37
4.5 Frequency of strikes to a structure	40
5 Principles of protection	43
5.1 Need for protection	43
5.2 Design considerations	48
5.3 Thermal considerations	51
5.4 Mechanical considerations	55
5.5 Electrical considerations	56
6 Materials and dimensions	61
6.1 Conductors for use above ground	61
6.2 Conductors for use below ground	64
6.3 Corrosion	65

x	<i>Lightning Protection</i>	
7	Protective systems for domestic, industrial and public structures	68
7.1	Air-termination network	68
7.2	Down conductors	75
7.3	Earth-termination network	83
7.4	Earth electrodes	89
7.5	Joints	95
7.6	Metal components on and in buildings	96
7.7	Sound and television aerials	100
7.8	Electricity supply and telephone installations	102
7.9	Structures with flammable roofs and farm buildings	105
8	Protection of tall structures	108
8.1	High-rise buildings	108
8.2	Chimneys and cooling towers	111
8.3	Churches and monuments	113
8.4	Telecommunication structures	117
9	Protection of danger structures	123
9.1	General considerations	123
9.2	Structures above ground	127
9.3	Structures below ground	132
9.4	Mining and blasting	133
9.5	Aircraft	139
9.6	Warning devices	144
10	Protection of miscellaneous structures	147
10.1	Temporary structures	147
10.2	Mobile structures	149
10.3	Agricultural objects	150
10.4	Structures on rock	152
10.5	Playing fields and public highways	153
10.6	Trees	157
10.7	Ships and boats	161
11	Maintenance	164
11.1	General considerations	164
11.2	Test methods	166
11.3	Inspection and records	169

12 Protection of persons and animals	172
12.1 Effects of lightning currents	172
12.2 Protection in the open	181
12.3 Protection indoors	187
12.4 Lightning casualties and resuscitation	188
13 Postscript	195
Appendix – National Codes considered in text	198
References	199
Author Index	213
Subject Index	216